



Douglas A. Ducey | Governor

Mark W. Killian | Director

Stage I Vapor Recovery Inspection Log

Shall be completed at least once every 7 days under A.A.C R3-7-1007(C)

Shall be maintained under A.A.C. R3-7-1009(A)

UNDERGROUND STORAGE TANKS		WEEK 1		WEEK 2		WEEK 3		WEEK 4		WEEK 5	
		DATE:		DATE:		DATE:		DATE:		DATE:	
		YES/NO	INITIAL								
1	Are the spill containment buckets clean and dry?										
2	Are dust caps installed on all product and vapor adaptors?										
3	Are the dust caps firmly secured and unable to swivel freely?										
4	Are the vapor recovery adaptors properly sealed?										
5	Are the rubber gaskets installed underneath all dust caps?										
6	Is the fill tube collar in good condition and free of any cracks or dents?										
7	If you look down the fill tube, do you see any gaskets that are torn or out of place?										
8	Are there P/V vent valves on the vent risers?										
9	Do the P/V vent valves or risers (pipes) appear to have any damage?										

If you are experiencing problems with any of the items listed above, record the issue on your equipment maintenance log then make the necessary repairs and/or contact a service technician immediately.

Owner/Operator: _____ Date: _____

I certify this document to be accurate and complete as required under A.A.C. R3-7-1007(C) and A.A.C. R3-7-1009(A), and I acknowledge that failing to maintain this document, or falsifying this document, is a violation of the Arizona Administrative Code and subject to civil penalties under A.R.S. 3-3475.

Weights and Measures Services Division
 1688 W. Adams Street, Phoenix, Arizona 85007
 Metrology Laboratory: 4425 W. Olive Avenue, Glendale, AZ 85302
 (602) 542-4373 FAX: (623) 939-8586 agriculture.az.gov